

#### **TECHNICAL DATA**

## Fluke LVD1 Volt Light



#### SAFETY COMPLIANCE

Meets UL/ANSI 61010-1/CSA22.2 No. 61010-1 (2004) Pollution Degree 2

#### **EMC COMPLIANCE**

Meets EN 61326-1:2006, EN 61326-2-2:2006 CISPR 11

#### **OPERATING**

40 V ac to 300 V ac

#### **TEMPERATURE**

Operating: 0 °C to 50 °C ( 32 °F to 122 °F) Storage: -10 °C to 50 °C (-14 °F to 122 °F)

#### **ALTITUDE**

2000 m

#### **CLEANING**

Clean with damp cloth

#### **BATTERY LIFE**

Approximately 7 hours continuous

#### **WARRANTY**

One year

# Non-contact AC voltage detector and LED flashlight combined in one convenient, compact design, with exclusive dual-sensitivity.

Non-contact AC voltage detector and LED flashlight combined in one convenient, compact design. Exclusive dual-sensitivity provides fast answers in a wide range of situations. The voltage detector glows blue when it's near AC voltage, and glows red when it's at the source. Detects voltages from 40 V AC to 300 V AC. Voltage detector glows blue when sensing 50 Hz - 60 Hz within 2.5 - 13 cm (1 - 5 in) away from source. Ultra-bright white LED with 100,000 hour bulb life. AAA battery included.

### **Dual levels of detection sensitivity**

- · Blue indicates you are close to ac voltage
- Red indicates you're at the source
- Detects voltages from 40 V ac to 300 V ac
- Operating Temperature 0 °C to 50 °C
- Ultra-bright white LED
- 100,000 hour bulb
- · AAA battery included







## Fluke. Keeping your world up and running.®

#### Fluke Corporation

PO Box 9090, Everett, WA 98206 U.S.A.

Fluke Europe B.V. PO Box 1186, 5602 BD Eindhoven, The Netherlands

#### For more information call:

In the U.S.A. (800) 443-5853 or Fax (425) 446-5116 In Europe/M-East/Africa +31 (0) 40 2675 200 or Fax +31 (0) 40 2675 222 In Canada (800)-36-FLUKE or Fax (905) 890-6866 From other countries +1 (425) 446-5500 or

Fax +1 (425) 446-5116 Web access: http://www.fluke.com

©2005-2015 Fluke Corporation. Specifications subject to change without notice. Printed in U.S.A. 10/2015 6006484a-EN

Modification of this document is not permitted without written permission from Fluke Corporation.