

# Supplement

Manual Title: PQ400 Instructions  
Part Number: 4954885 Supplement Issue: 1  
Print Date: October 2018 Issue Date: 3/19  
Revision/Date: 1, 2/19 Page Count: 1

---

---

This supplement contains information necessary to ensure the accuracy of the above manual.

## Change #1, 691

On the 3<sup>rd</sup> page, replace the 6<sup>th</sup> bullet with:

- **Use a certified circuit breaker marked as the disconnecting device in an easily reached location suitable for the wire gauge used for the voltage inputs to the Product.**

On the 13<sup>th</sup> page, under **Environment**, replace the Humidity with:

Humidity.....10 % to 90 % (non-condensing) in dependency of temperature according to IEC 60721-3-3  
Class 3K6 (modified):  
-25 °C to 35 °C: 10 % to 90 %,  
50°C: max. 35 %,  
60°C: max. 23 %

On the 14<sup>th</sup> page, under **Voltage**, replace the Wire gauge with:

Wire gauge.....solid/flexible: 0.25 mm<sup>2</sup> to 1.5 mm<sup>2</sup>  
(AWG 24 to AWG 16), rated 65 °C min